

City of Greensboro
2016 Non-Detected Contaminants

Note: This list, coupled with the substances listed in the Consumer Confidence Report (CCR), comprises all contaminants monitored for in 2016.

Contaminant	Required Reporting Limit	Frequency tested at both water plants
Antimony	0.003 mg/L	Annually
Arsenic	0.005 mg/L	Annually
Barium	0.400 mg/L	Annually
Beryllium	0.002 mg/L	Annually
Cadmium	0.001 mg/L	Annually
Chromium	0.020 mg/L	Annually
Cyanide	0.050 mg/L	Annually
Iron	0.060 mg/L	Annually
Manganese	0.010 mg/L	Annually
Mercury	0.0004 mg/L	Annually
Nickel	0.100 mg/L	Annually
Selenium	0.010 mg/L	Annually
Thallium	0.001 mg/L	Annually
Nitrate	1.00 mg/L	Annually
Nitrite	0.10 mg/L	Annually
2,4,5-TP (Silvex)	0.0002 mg/L	Annually
2,4-D	0.0001 mg/L	Annually
Alachlor	0.0002 mg/L	Annually
Atrazine	0.0001 mg/L	Annually
Benzo(a)pyrene	0.00002 mg/L	Annually
Carbofuran	0.0009 mg/L	Annually
Chlordane	0.0002 mg/L	Annually
Dalapon	0.001 mg/L	Annually
DBCP	0.00002 mg/L	Annually
Di(2-ethylhexyl)adipate	0.0006 mg/L	Annually
Di(2-ethylhexyl)Phthalate	0.00132 mg/L	Annually
Dinoseb	0.0002 mg/L	Annually
Endrin	0.00001 mg/L	Annually
Ethylene Dibromide (EDB)	0.00001 mg/L	Annually
Heptachlor	0.00004 mg/L	Annually
Heptachlor Epoxide	0.00002 mg/L	Annually
Hexachlorobenzene	0.0001 mg/L	Annually
Hexachlorocyclopentadiene	0.0001 mg/L	Annually
Lindane	0.00002 mg/L	Annually
Methoxychlor	0.0001 mg/L	Annually
Oxamyl(vydate)	0.002 mg/L	Annually
PCBs (as decachlorobiphenol)	0.0001 mg/L	Annually
Pentachlorophenol	0.00004 mg/L	Annually
Picloram	0.0001 mg/L	Annually
Simazine	0.00007 mg/L	Annually
Toxaphene	0.001 mg/L	Annually

City of Greensboro
2016 Non-Detected Contaminants

Contaminant	Required Reporting Limit	Frequency tested at both water plants
1,2,4-Trichlorobenzene	0.0005 mg/L	Annually
1,1,1-Trichloroethane	0.0005 mg/L	Annually
1,1,2-Trichloroethane	0.0005 mg/L	Annually
1,1-Dichloroethylene	0.0005 mg/L	Annually
1,2-Dichloroethane	0.0005 mg/L	Annually
1,2-Dichloropropane	0.0005 mg/L	Annually
Benzene	0.0005 mg/L	Annually
Carbon Tetrachloride	0.0005 mg/L	Annually
Chlorobenzene	0.0005 mg/L	Annually
Cis-1,2-Dichloroethylene	0.0005 mg/L	Annually
Dichloromethane	0.0005 mg/L	Annually
Ethylbenzene	0.0005 mg/L	Annually
o-Dichlorobenzene	0.0005 mg/L	Annually
p-Dichlorobenzene	0.0005 mg/L	Annually
Styrene	0.0005 mg/L	Annually
Tetrachloroethylene	0.0005 mg/L	Annually
Toluene	0.0005 mg/L	Annually
Trans-1,2-Dichloroethylene	0.0005 mg/L	Annually
Trichloroethylene	0.0005 mg/L	Annually
Vinyl Chloride	0.0005 mg/L	Annually
Xylenes (Total)	0.0005 mg/L	Annually