

*City of Reidsville*  
**2018 Annual Drinking Water Quality Report**  
Water System Number: 02-79-020

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot 2018 calendar year's water quality. Included are details about your source(s) of water, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information because informed customers are our best allies. **If you have any questions about this report or concerning your water, please contact Scott Jewell at 336-342-4002. We want our valued customers to be informed about their water utility.**

### **What EPA Wants You to Know**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Reidsville is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. If your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

### **When You Turn on Your Tap, Consider the Source**

The water that is used by this system is surface water from Lake Reidsville and is located at 278 Reid Lake Road, Reidsville, NC 27320.

## Source Water Assessment Program (SWAP) Results

The North Carolina Department of Environment and Natural Resources (DENR), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate or Lower.

The relative susceptibility rating of each source for City of Reidsville was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area). The assessment findings are summarized in the table below:

The complete SWAP Assessment report for City of Reidsville-Lake Reidsville may be viewed on the Web at:


<https://www.ncwater.org/?page=600> Note that because SWAP results and reports are periodically updated by the PWS Section, the results available on this web site may differ from the results that were available at the time this CCR was prepared. If you are unable to access your SWAP report on the web, you may mail a written request for a printed copy to: Source Water Assessment Program – Report Request, 1634 Mail Service Center, Raleigh, NC 27699-1634, or email requests to [swap@ncdenr.gov](mailto:swap@ncdenr.gov). Please indicate your system name, number, and provide your name, mailing address and phone number. If you have any questions about the SWAP report please contact the Source Water Assessment staff by phone at 919-707-9098.

### Susceptibility of Sources to Potential Contaminant Sources (PCSs)

Source Name	Susceptibility Rating	SWAP Report Date
Lake Reidsville	Moderate	July13, 2015

## Help Protect Your Source Water-Lake Reidsville & Lake Hunt

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water sources in several ways: (examples: dispose of chemicals properly; take used motor oil to a recycling center, using recycling services to keep our creeks and streams free of wastes and volunteer in your community to participate in group efforts to protect your water source). Farmers can also utilize cover crops to prevent year round erosion and soil runoff. Source water protection is a community effort.



## Violations that Your Water System Received for the Report Year

During 2018, or during any compliance period that ended in 2018, we received 2 violations that covered the time period of January 1, 2018-December 31, 2018. Please see the Public Notice for the Tier 3 violation of the Total Coliform Rule.

During 2018, or during any compliance period that ended in , we received a treatment technique violation of the Surface Water Treatment Rule, the NC Drinking Water Act and Rules Governing Public Water Systems violation that covered the time period of May 30, 2018. We have conducted 3 meetings on June 6, 2018 and July 17, 2018 with our team of Operators and maintenance staff to discuss the issue and to implement procedures to assure this does not happen again. We have implemented stricter guidelines for our finished water monitoring devices and are installing finished chlorine monitors that will alarm and notify the Operator if this problem occurs.

### Treatment Technique Violations

TT Violation	Explanation	Length of Violation	Steps Taken to Correct the Violation	Health Effects Language
Treatment Technique- The residual disinfection was less than 1.0mg/L in finished water to the City of Greensboro.	Operator failed to recognize that chlorine equipment was not functioning properly under 4 hours.	4 hours 7 minutes	We have conducted 3 meetings on June 6, 2018 and July 17, 2018 with our team of Operators and maintenance staff to discuss the issue and to implement procedures and install new equipment to assure this does not happen again. We have implemented stricter guidelines for our finished water monitoring devices and are installing finished chlorine monitors that will alarm and notify the Operator if this problem occurs.	Disinfection treatment process must be sufficient to ensure inactivation and/or removal of Giardia lamblia cysts and viruses from your drinking water. The symptoms of giardiasis range from being asymptomatic (having no symptoms) to having severe chronic (long-lasting or frequently-recurring) diarrhea. The incubation period is usually between three to twenty-five days, with an average of about seven. Primary symptoms of giardiasis include: diarrhea, stomach cramps, upset stomach, nausea, vomiting and low-grade fever (fever up to 102°F). These symptoms can lead to weight loss and dehydration.

### Water Quality Data Tables of Detected Contaminants

We routinely monitor for over 150 contaminants in your drinking water according to Federal and State laws. The tables below list all the drinking water contaminants that we detected in the last round of sampling for each particular contaminant group. The presence of contaminants does not necessarily indicate that water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2018. The EPA and the State allow us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old. Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulations are warranted.

# NOTICE TO THE PUBLIC – Reporting Violation

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Reporting Requirement(s) Not Met for [City of Reidsville]

We are required to report the results of monitoring of your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During the [monthly](#) compliance period beginning [April 1, 2018](#) we did not report the results of monitoring due to a computer glitch for Total Coliform (routine sample) within the required timeframe.

Our system failed to notify the state drinking water program as required by [May 10, 2018](#) for the sample at 1007 Windermere Court, Reidsville, NC 27320. Although public health was not impacted, as our customers, you have a right to know what happened and what we did to correct the situation.

### What should I do?

There is nothing you need to do at this time. You do not need to boil your water or take other actions.

### What is being done?

While we did not notify the state as quickly as we should have, we have submitted the negative results to the State on June 7, 2018. Due to this computer glitch, we are now double-checking our monthly submittals in order to ensure proper delivery of the results to the State. We are no longer in violation.

***Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.***

For more information, please contact:

Responsible Person Scott Jewell	System Name City of Reidsville	System Address (Street) 278 Reid Lake Road
Phone Number 336-342-4002	System Number NC0279020	System Address (City, State, Zip) Reidsville, NC 27302

Notice of Violation Date: August 2, 2018

Date Notice Distributed: May 15, 2019 Method of Distribution: CCR & Direct Mail to Customer

### Public Notification Certification:

The public water system named above hereby affirms that public notification has been provided to its consumer in accordance with all delivery, content, format, and deadline requirements specified in 15A NCAC 18C .1523.

Owner/Operator: *C. Scott Jewell*  
(Signature)

C. Scott Jewell  
(Print Name)

March 29, 2019  
(Date)

**Important Drinking Water Definitions:**

***Not-Applicable (N/A)*** – Information not applicable/not required for that particular water system or for that particular rule.

***Non-Detects (ND)*** - Laboratory analysis indicates that the contaminant is not present at the level of detection set for the particular methodology used.

***Parts per million (ppm) or Milligrams per liter (mg/L)*** - One part per million corresponds to one minute in two years or a single penny in \$10,000.

***Parts per billion (ppb) or Micrograms per liter (ug/L)*** - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

***Parts per trillion (ppt) or Nanograms per liter (nanograms/L)*** - One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

***Parts per quadrillion (ppq) or Picograms per liter (picograms/L)*** - One part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

***Picocuries per liter (pCi/L)*** - Picocuries per liter is a measure of the radioactivity in water.

***Million Fibers per Liter (MFL)*** - Million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

***Nephelometric Turbidity Unit (NTU)*** - Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

***Action Level (AL)*** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

***Treatment Technique (TT)*** - A required process intended to reduce the level of a contaminant in drinking water.

***Maximum Residual Disinfection Level (MRDL)*** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

***Maximum Residual Disinfection Level Goal (MRDLG)*** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

***Locational Running Annual Average (LRAA)*** – The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters under the Stage 2 Disinfectants and Disinfection Byproducts Rule.

***Maximum Contaminant Level (MCL)*** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

***Maximum Contaminant Level Goal (MCLG)*** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

***UCMR4-Unregulated Contaminant Monitoring Rule 4***

***Minimum Reporting Limit-(MRL)***

---

## Tables of Detected Contaminants

### Microbiological Contaminants in the Distribution System - For systems that collect *less than 40* samples per month

Contaminant (units)	MCL Violation Y/N	Your Water	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria (presence or absence)	N	ND	0	1 positive sample / month*	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (presence or absence)	N	ND	0	Note: If either an original routine sample and/or its repeat samples(s) are fecal coliform or <i>E. coli</i> positive, a Tier 1 violation exists.	Human and animal fecal waste

### Turbidity\*

Contaminant (units)	Treatment Technique (TT) Violation Y/N	Your Water	MCLG	Treatment Technique (TT) Violation if:	Likely Source of Contamination
Turbidity (NTU) - Highest single turbidity measurement	N	0.23 NTU	N/A	Turbidity > 1 NTU	Soil runoff
Turbidity (NTU) - Lowest monthly percentage (%) of samples meeting turbidity limits	N	100%	N/A	Less than 95% of monthly turbidity measurements are ≤ 0.3 NTU	

\* Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. The turbidity rule requires that 95% or more of the monthly samples must be less than or equal to 0.3 NTU.

### Inorganic Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Antimony (ppb)	01-10-18	N	ND	N/A	N/A	6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Arsenic (ppb)	01-10-18	N	ND	N/A	N/A	0	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium (ppm)	01-10-18	N	ND	N/A	N/A	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Beryllium (ppb)	01-10-18	N	ND	N/A	N/A	4	4	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	01-10-18	N	ND	N/A	N/A	5	5	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppb)	01-10-18	N	ND	N/A	N/A	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Cyanide (ppb)	01-10-18	N	ND	N/A	N/A	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Fluoride (ppm)	01-10-18	N	0.38	N/A	N/A	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Mercury (inorganic) (ppb)	01-10-18	N	ND	N/A	N/A	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
Selenium (ppb)	01-10-18	N	ND	N/A	N/A	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Thallium (ppb)	01-10-18	N	ND	N/A	N/A	0.5	2	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Total Asbestos (MFL)	11-14-11	N	ND	n/a	n/a	7	7	Decay of asbestos cement water mains; erosion of natural deposits

### Nitrate/Nitrite Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Nitrate (as Nitrogen) (ppm)	01-10-18	N	ND	N/A		10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrite (as Nitrogen) (ppm)	01-10-18	N	ND	N/A		1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

### Synthetic Organic Chemical (SOC) Contaminants Including Pesticides and Herbicides

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
2,4-D (ppb)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A		70	70	Runoff from herbicide used on row crops
2,4,5-TP (Silvex) (ppb)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A		50	50	Residue of banned herbicide
Alachlor (ppb)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A		0	2	Runoff from herbicide used on row crops
Atrazine (ppb)	3-7-18 6-13-18 *7-11-18 9-19-18 10-24-18	N	*0.24	0	0.24	3	3	Runoff from herbicide used on row crops
Benzo(a)pyrene (PAH) (ppt)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A		0	200	Leaching from linings of water storage tanks and distribution lines
Carbofuran (ppb)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A		40	40	Leaching of soil fumigant used on rice and alfalfa
Chlordane (ppb)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A		0	2	Residue of banned termiticide
Dalapon (ppb)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A		200	200	Runoff from herbicide used on rights of way
Di(2-ethylhexyl) adipate (ppb)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A		400	400	Discharge from chemical factories
Di(2-ethylhexyl) phthalate (ppb)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A		0	6	Discharge from rubber and chemical factories
DBCP [Dibromochloropropane] (ppt)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A		0	200	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards
Dinoseb (ppb)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A		7	7	Runoff from herbicide used on soybeans and vegetables

Endrin (ppb)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A	2	2	Residue of banned insecticide
EDB [Ethylene dibromide] (ppt)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A	0	50	Discharge from petroleum refineries
Heptachlor (ppt)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A	0	400	Residue of banned pesticide
Heptachlor epoxide (ppt)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A	0	200	Breakdown of heptachlor
Hexachlorobenzene (ppb)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A	0	1	Discharge from metal refineries and agricultural chemical factories
Hexachlorocyclopentadiene (ppb)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A	50	50	Discharge from chemical factories
Lindane (ppt)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A	200	200	Runoff/leaching from insecticide used on cattle, lumber, gardens
Methoxychlor (ppb)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A	40	40	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock
Oxamyl [Vydate] (ppb)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A	200	200	Runoff/leaching from insecticide used on apples, potatoes and tomatoes
PCBs [Polychlorinated biphenyls] (ppt)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A	0	500	Runoff from landfills; discharge of waste chemicals
Pentachlorophenol (ppb)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A	0	1	Discharge from wood preserving factories
Picloram (ppb)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A	500	500	Herbicide runoff
Simazine (ppb)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A	4	4	Herbicide runoff
Toxaphene (ppb)	3-7-18 6-13-18 7-11-18 9-19-18 10-24-18	N	ND	N/A	0	3	Runoff/leaching from insecticide used on cotton and cattle



### Volatile Organic Chemical (VOC) Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Benzene (ppb)	01-10-18	N	ND	N/A		0	5	Discharge from factories; leaching from gas storage tanks and landfills
Carbon tetrachloride (ppb)	01-10-18	N	ND	N/A		0	5	Discharge from chemical plants and other industrial activities
Chlorobenzene (ppb)	01-10-18	N	ND	N/A		100	100	Discharge from chemical and agricultural chemical factories
o-Dichlorobenzene (ppb)	01-10-18	N	ND	N/A		600	600	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	01-10-18	N	ND	N/A		75	75	Discharge from industrial chemical factories
1,2 – Dichloroethane (ppb)	01-10-18	N	ND	N/A		0	5	Discharge from industrial chemical factories
1,1 – Dichloroethylene (ppb)	01-10-18	N	ND	N/A		7	7	Discharge from industrial chemical factories
cis-1,2-Dichloroethylene (ppb)	01-10-18	N	ND	N/A		70	70	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	01-10-18	N	ND	N/A		100	100	Discharge from industrial chemical factories
Dichloromethane (ppb)	01-10-18	N	ND	N/A		0	5	Discharge from pharmaceutical and chemical factories
1,2-Dichloropropane (ppb)	01-10-18	N	ND	N/A		0	5	Discharge from industrial chemical factories
Ethylbenzene (ppb)	01-10-18	N	ND	N/A		700	700	Discharge from petroleum refineries
Styrene (ppb)	01-10-18	N	ND	N/A		100	100	Discharge from rubber and plastic factories; leaching from landfills
Tetrachloroethylene (ppb)	01-10-18	N	ND	N/A		0	5	Discharge from factories and dry cleaners
1,2,4 –Trichlorobenzene (ppb)	01-10-18	N	ND	N/A		70	70	Discharge from textile-finishing factories
1,1,1 – Trichloroethane (ppb)	01-10-18	N	ND	N/A		200	200	Discharge from metal degreasing sites and other factories
1,1,2 –Trichloroethane (ppb)	01-10-18	N	ND	N/A		3	5	Discharge from industrial chemical factories
Trichloroethylene (ppb)	01-10-18	N	ND	N/A		0	5	Discharge from metal degreasing sites and other factories
Toluene (ppm)	01-10-18	N	ND	N/A		1	1	Discharge from petroleum factories
Vinyl Chloride (ppb)	01-10-18	N	ND	N/A		0	2	Leaching from PVC piping; discharge from plastics factories
Xylenes (Total) (ppm)	01-10-18	N	ND	N/A		10	10	Discharge from petroleum factories; discharge from chemical factories

### Lead and Copper Contaminants

Contaminant (units)	Sample Date	Your Water	Number of sites found above the AL	MCLG	AL	Likely Source of Contamination
Copper (ppm) (90 <sup>th</sup> percentile)	6/5/18 - 6/25/18	0.071	0	1.3	AL=1.3ppm	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb) (90 <sup>th</sup> percentile)	6/5/18 - 6/25/18	ND	0	0	AL=15ppb	Corrosion of household plumbing systems; erosion of natural deposits

### Radiological Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Alpha emitters (pCi/L)	1/18/17	N	ND	N/A		0	15	Erosion of natural deposits
Radon	1/18/17	N	ND	N/A		0	N/A	Occurs naturally in radioactive decay
Beta/photon emitters (pCi/L)	1/18/17	N	ND	N/A		0	50 *	Decay of natural and man-made deposits
Combined radium (pCi/L)	1/18/17	N	ND	N/A		0	5	Erosion of natural deposits

Uranium (pCi/L)	1/18/17	N	ND	N/A	0	20.1	Erosion of natural deposits
-----------------	---------	---	----	-----	---	------	-----------------------------

\* Note: The MCL for beta/photon emitters is 4 mrem/year. EPA considers 50 pCi/L to be the level of concern for beta particles.

### Total Organic Carbon (TOC)

Contaminant (units)	TT Violation Y/N	Your Water (RAA Removal Ratio)	Range Monthly Removal Ratio Low - High	MCLG	TT	Likely Source of Contamination	Compliance Method (Step 1 or ACC#_)
Total Organic Carbon (removal ratio) (TOC)-TREATED	N	1.16	0.93-1.54	N/A	TT	Naturally present in the environment	Step 1

### Disinfectant Residuals Summary

	Year Sampled	MRDL Violation Y/N	Your Water (highest RAA)	Range		MRDLG	MRDL	Likely Source of Contamination
				Low	High			
Chloramines (ppm)	2018	N	3.53	2.41	3.71	4	4.0	Water additive used to control microbes

**For TTHM:** *Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.*

**For HAA5:** *Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.*

### Stage 2 Disinfection Byproduct Compliance - Based upon Locational Running Annual Average (LRAA)ppb

Disinfection Byproduct	Year Sampled	MCL Violation Y/N	Your Water (highest LRAA)	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
TTHM (ppb)						N/A	80	Byproduct of drinking water disinfection
B01	2018	N	39	12	65	N/A	80	
B02	2018	N	38	28	55	N/A	80	
B03	2018	N	39	27	70	N/A	80	
B04	2018	N	38	18	62	N/A	80	
HAA5 (ppb)						N/A	60	Byproduct of drinking water disinfection
B01	2018	N	34	19	59	N/A	60	
B02	2018	N	37	27	55	N/A	60	
B03	2018	N	35	27	57	N/A	60	
B04	2018	N	33	19	48	N/A	60	

The PWS Section requires monitoring for other misc. contaminants, some for which the EPA has set national secondary drinking water standards (SMCLs) because they may cause cosmetic effects or aesthetic effects (such as taste, odor, and/or color) in drinking water. The contaminants with SMCLs normally do not have any health effects and normally do not affect the safety of your water.

**Other Miscellaneous Water Characteristics Contaminants -**

Contaminant (units)	Sample Date	Your Water	Range		SMCL
			Low	High	
Iron (ppm)	01-10-18	ND	N/A		0.3 mg/L
Manganese (ppm)	11-20-18 (UCMR4) 01-10-18	0.0274 mg/L ND	N/A		0.05 mg/L
Nickel (ppm)	01-10-18	ND	N/A		N/A
Sodium (ppm)	01-10-18	24.510 mg/L	N/A		N/A
Sulfate (ppm)	01-10-18	28.8 mg/L	N/A		250 mg/L
pH	01-10-18	7.9 units	N/A		6.5 to 8.5

***Cryptosporidium sp.***

*Cryptosporidium sp.* is a microbial pathogen found in surface water throughout the U.S. Effective removal of this organism is accomplished during the normal treatment process of coagulation, sedimentation, filtration and disinfection. remove *Cryptosporidium sp.*, the most commonly-used filtration methods cannot guarantee 100 percent removal. Our monitoring indicates the presence of these organisms in our source water and/or finished water. Current test methods do not allow us to determine if the organisms are dead or if they are capable of causing disease. Ingestion of *Cryptosporidium sp.* may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, immuno-compromised people, HIV-AIDS patients, infants and small children, and the elderly are at greater risk of developing life-threatening illness. We encourage immuno-compromised individuals to consult their doctor regarding appropriate precautions to take to avoid infection. *Cryptosporidium sp.* must be ingested to cause disease, and it may be spread through means other than drinking water. The Environmental Protection Agency and the Center for Disease Control guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium sp.* and other microbiological contaminants are available from the Safe Drinking Water Act Hotline at (800) 426-4791.

Please note that all samples were sent to a certified laboratory for testing. Our system monitored Lake Reidsville for *Cryptosporidium* once a month during the year 2018 and found levels of the following.

Location	Samples Collected	Total Oocysts Collected	Total Oocysts/Liter-April 2017 Sample	Average Concentration	Concentration Requiring Additional Treatment
Lake Reidsville	12 (120 liters)	1	0.091	0.0083 oocysts/liter	0.075 oocysts/liter

**Additional Monitoring of Other Contaminants Disinfection Byproducts (UCMR4)**

Disinfection Byproduct	Date Sampled	MCL Violation Y/N	Your Water	MRL	Units	Likely Source of Contamination
Bromochloroacetic Acid						Byproduct of drinking water disinfection
B01	11-21-18	N	1.80	0.300	ug/L	
B02	11-21-18	N	1.91	0.300	ug/L	
B03	11-21-18	N	1.98	0.300	ug/L	
B04	11-21-18	N	1.69	0.300	ug/L	
Bromodichloroacetic Acid						Byproduct of drinking water disinfection
B01	11-21-18	N	1.26	0.500	ug/L	

B02	11-21-18	N	1.49	0.500	ug/L	
B03	11-21-18	N	1.48	0.500	ug/L	
B04	11-21-18	N	1.29	0.500	ug/L	
Dichloroacetic Acid						Byproduct of drinking water disinfection
B01	11-21-18	N	20.1	0.200	ug/L	
B02	11-21-18	N	24.9	0.200	ug/L	
B03	11-21-18	N	24.0	0.200	ug/L	
B04	11-21-18	N	19.1	0.200	ug/L	
Trichloroacetic Acid						Byproduct of drinking water disinfection
B01	11-21-18	N	13.0	0.500	ug/L	
B02	11-21-18	N	14.7	0.500	ug/L	
B03	11-21-18	N	14.7	0.500	ug/L	
B04	11-21-18	N	13.7	0.500	ug/L	



With the recent events in Flint, Michigan, the importance of safe drinking water has never been more apparent. Providing a safe and reliable source of drinking water for our community, businesses and citizens is top priority. Protecting public health is the major concern in every Water and Wastewater facility in America. And, it all begins with protecting our source water, Lake Reidsville.

Each citizen can play a special role in protecting our local source. A collective and collaborative effort will ensure a safe and reliable supply for now and in the future. Ask yourself, what can I do to help? Do you recycle used motor oil? Do you over fertilize your yards? Do you sweep and properly recycle grass clippings? Do you recycle plastics? Do you clean-up chemical or gas spills and dispose properly? Do you “dump” items down the stormwater drains? Be smart about potential causes of source water contamination.

Clean water is a vital part of every community. Water is the molecule of life and its valuable resources are limited. Our dialysis patients, local industry and every home in our community is dependent upon a safe and reliable delivery of clean water 24 hours a day, 7 days a week and 365 days a year.

## ***Safe & Reliable Water-Our Communities' Future!!***

### Source Water Protection Additional Resources

Pocket Guide for Source Water Protection: <https://www.epa.gov/sourcewaterprotection/additional-resources-citizen-involvement-source-water-protection>

NC Source Water Assessment Program: <http://www.enr.state.nc.us/flighttest/pages/swaplink.htm>

