



City of Greensboro: Development Services
Commercial Fire Protection System Permit Application

300 W. Washington St.
 Greensboro, NC 27401 (336) 373-7694 Fax (336) 333-6056

For review status:
www.greensboro-nc.gov/planreview

Date: _____

Company Name: _____

Company Address: _____

Check one: Designer Contractor Owner/Tenant

Contact Person: _____ Phone: _____ Fax: _____

Email: _____

The Contact Person will receive all the correspondence, notices and comments.

Project Name: _____

Project Address: _____

Type of fire protection system (check one):

- Fire Alarm Sprinkler / Standpipe / Fire Pump Commercial Cooking System (AES)
 Clean Agent System (AES) Dry Chemical System (AES) CO2 / Inert Gas (AES) AST/UST
 ERRC (Emergency Responder Radio Coverage-contact us for requirements) Other (specify)

Description of Work: _____

Work Area: _____ SF

Plan Review fees: Checks should be made payable to the "City of Greensboro"

\$125.00 for fire alarm systems; sprinkler system(s) per riser; standpipe/fire pump; \$75.00 for Commercial Hood Systems, Spray Booths; and AST/UST per tank.

Submittal requirements:

Fire Alarm Systems: All fire alarm systems require two (2) sets of Professionally Engineered (PE) signed and sealed plans. If PE signed fire alarm plans are included in the electrical plans for building plan submittal, shop drawings will suffice. Battery calculations need to be included in the plans. Include (2) sets of cut sheets for all devices.

Sprinkler Systems /Standpipe / Fire Pump: All sprinkler systems require two (2) sets of NICETT Level III plans with hydraulic calculations, cut sheets on heads and pipe materials, Site plan/Underground with FDC/hydrants, and a current (< 12 month) water flow test from Greensboro Water Resources. Include fire pump test curve when applicable.

AES: All AES require two (2) sets of plans showing tank, flow points, nozzles used and the heights. Plans must show appliances, pipe sizes, duct sizes, and pull station location. Acknowledge class K extinguisher (when required) and interconnection with fire alarm system (if present). Include a current manufacturer's issued certification for the installer.

AST / UST: All tanks require two (2) sets of Professionally Engineered (PE) sealed plans showing site plan with tank location, cut sheets for tank (s) with MSDS for product and secondary containment.

EMERGENCY REPAIRS AND WORK: For emergency repairs and work notify Emergency Permitting by email at FirePlans@greensboro-nc.gov

Required information in Emergency Permitting email:

1. Your name

(Continued on Page 2)



City of Greensboro: Development Services
Commercial Fire Protection System Permit Application

300 W. Washington St.

Greensboro, NC 27401 (336) 373-7694 Fax (336) 333-6056

For review status:

www.greensboro-nc.gov/planreview

(Continued from Page 1)

2. The name of the company you work for
3. Your phone number
4. The address where the work is being done
5. The scope of work being done
6. Title of email shall be "Emergency Permitting"

After emailing Emergency Permitting you may begin the work. We will contact you during regular business hours with your next steps for the emergency permit process. As a reminder- Maintenance work is not emergency work.

I hereby certify that all information in this application is correct. Fire Plans Review will be notified of any changes in the approved plans and specifications for the system permitted herein. Plans will not be reviewed without a completed permit application and payment.

Applicant Signature

Updated 1/14/2020